

Robert P. Astorino
County Executive

Sherlita Amler, M.D.
Commissioner of Health

Village of Tarrytown
One Depot Plaza
Tarrytown, NY 10591
Attn: Michael Blau, Village Administrator

February 24 2014

RE: Notice of Lead Action Level Exceedance
Village of Tarrytown Water System
Tarrytown (V)
PWS ID: NY 5903461

Dear Mr. Blau:

A review of first draw lead and copper tap sampling results for the above referenced public water supply for the monitoring period beginning January 1, 2011 and ending December 31, 2013 revealed that the 90th percentile lead level exceeded the action level of 0.015 milligrams per liter (mg/l) with a specific value of 0.016 mg/l. This constitute non compliance with Part 5, Subpart 5-1, Section 5-1.41(a) of the New York State Sanitary Code (NYSSC).

Due to the exceedance of the 90th percentile Lead Action Level, the water system must notify and deliver education materials to its consumers in accordance with Part 5, Subpart 5-1, Section 5-1.44 of NYSSC within thirty (30) days from the date of this notice. A draft of the notice must be submitted to this Department for review prior to distribution. Further, certification that the above notification was made and a copy of such notification must be submitted to the Department within ten (10) days of the completion of the notification requirements.

The continued monitoring of First Draw Lead and Copper Tap Sampling must be performed at the standard number of monitoring sites on a six (6) month schedule beginning with the monitoring period of January 1, 2014 - June 30, 2014. In addition, water quality parameter monitoring must be performed during this period in accordance with Part 5, Subpart 5-1, Section 5-1.43 and 5-1.47 of NYSSC. Water system must establish the water quality parameters values for optimal corrosion control treatment and maintain the specified limits or ranges for two (2) consecutive six month monitoring periods to be eligible for reduced monitoring.

Should you have any questions, please contact Zaw Thein, Assistant Engineer at (914) 864-7348 or myself at (914) 864- 7296.

Very truly yours,



Delroy Taylor, P.E.,
Associate Engineer
Bureau of Environmental Quality

DT:zt

cc: Michael McGarvey, P.E., Village Engineer, Tarrytown (V)
Steve Cowles, Water System Operator, Tarrytown (V)
Anna Stamm, P.E., NYSDOH
File ✓